



***“Potential energy savings deriving from  
the lighting system renovation in a  
community clinic”***

A. Carbonari, L. Nobili, R. Pontoni  
(speaking)

**DICEA Department - Division of Building Technologies  
Research Team: Building Construction and Automation**

[www.univpm.it](http://www.univpm.it)

**Polytechnic University of Marche - Ancona, Italy**

# OUTLINE

- Objective: EPC contracting
- The case study: a community clinic
- Measured consumption and energy breakdown
- Future scenarios
- Simulations
- Opportunities
- Assessment of energy savings and payback
- Conclusions

## OBJECTIVE

EU Directive 2012/27/EU: public administration's energy improvement.

EPC: Energy performance contracting

Consumption of public buildings is so high that some renovation scenarios have a very short payback period and can be managed directly by facility management companies.

From literature:

- lighting usually represents between 20% and 30% of the overall electric consumption;
- savings opportunities using daylight illumination have been estimated between 20% and 80% of lighting consumption.

## OUR CASE STUDY


Petritoli's Community Clinic, near Fermo (Italy).

Net surface: 3807 m<sup>2</sup>

Gross volume: 18676 m<sup>3</sup>

Centralized heating plant


It hosts: radiology, emergency, physiotherapy, medical offices, psychiatric ward, hospitalization (20 beds).



# OVERALL ENERGY BREAKDOWN (measured)

Comparison in terms of primary energy:

Hospital's whole consumption Petritoli




Electric power consumption:

YEAR-MONTH	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL	
<i>1 - Fuel Consumption Gas Atelung (m³)</i>														
2011	7384	10051	7451	3219	1106	904	793	633	829	1109	5051	9720	48328	
2012	6309	9627	7660	3383	944	924	752	601	787	1052	4793	9220	48120	
2013	5986	9163	7268	3108	896	905	771	631	667	965	4815	9309	46484	
<i>2 - Fuel Consumption for Hot Water (m³)</i>														
2011	896	896	896	800	1106	904	793	633	829	1109	896	896	10747	
2012	801	801	801	801	806	806	752	601	787	1052	801	801	9507	
2013	806	806	806	806	896	905	771	631	667	965	806	806	9670	
<i>3 - Fuel Consumption for Heating (m³)</i>														
2011	6489	9195	6595	3314								4156	8831	37580
2012	5508	8856	6829	4583								3992	8428	38228
2013	5180	8357	6462	4392								4009	8503	36814
<i>4 - Electrical Power Consumption (kWh)</i>														
2011	12849	5180	5282	7419	9016	7096	7033	0	9991	5010	5719	6088	81583	
2012	8506	8264	7210	6478	5544	5344	5263	5357	5388	5974	7441	8064	79133	
2013	8341	7431	4152	7431	5640	5379	5600	5806	5748	6583	8026	6350	76487	
<i>5 - Total Primary Energy (kWh)</i>														
2011	74610	10057	75634	33751	12755	10816	9742	8330	10101	12780	53326	97080	498395	
2012	64291	9644	72233	24693	9874	9874	9553	7989	9624	12336	49748	93498	493537	
2013	61192	91676	73494	21961	10740	10826	9240	8197	8243	11402	49529	93076	480608	


# THERMAL ENERGY BREAKDOWN (simulated)

Software used for simulation: MC4Suite2013


Calculation methods: UNI TS 11300-1 (from UNI EN ISO 13790:2008) and UNI TS 11300-2 .



Thermal plant:  
on the ground floor (centralized).  
Boiler: Biasi AR250 (290 kW).  
A tank for hot water storage.  
Two circuits (heating/hot water).



Validation (< 1% error):



# ELECTRIC ENERGY BREAKDOWN (simulated)

From behavioral models (data source: interviews and on-site surveys; implementation: Excel spreadsheet):

YEAR\MONTH	JEN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
<i>1 – Electrical Power Consumption [kWh<sub>el</sub>]</i>													
2011-12-13 <sub>Mean</sub>	8666	8420	7346	6600	5648	5445	5668	5458	5489	6086	7581	8216	80622
<i>2. – Auxiliary Consumption for Heating [kWh<sub>el</sub>]</i>													
2011-12-13 <sub>Mean</sub>	1111.7	1111.7	1111.7	555.8							1111.7	1111.7	6114.2
<i>3. – Auxiliary Consumption for Hot Water [kWh<sub>el</sub>]</i>													
2011-12-13 <sub>Mean</sub>	807.8	807.8	807.8	807.8	807.8	807.8	807.8	807.8	807.8	807.8	807.8	807.8	9694.1
<i>4 – Building Electrical Power Consumption [kWh]</i>													
2011-12-13 <sub>Mean</sub>	7059	6812	5738	5338	4733	4529	4752	4542	4754	5171	5974	6608	65827
<i>5 – Equipment Electrical Power Consumption [kWh]</i>													
2011-12-13 <sub>Mean</sub>	2113	2113	2113	2113	2113	2113	2113	2113	2113	2113	2113	2113	25352
<i>6 – Lighting Electrical Power Consumption [kWh]</i>													
2011-12-13 <sub>Mean</sub>	4946	4699	3625	3226	2620	2416	2639	2429	2461	3058	3861	4496	40475

Database about lighting: fixtures; lamps; power; socket; control gear; daily use; weekly use; monthly use; monthly consumption; annual consumption.

# RENOVATION SCENARIOS FOR LIGHTING

List of combinations:

Scenario Code	Description
SC1+2 (scenarios no. 1 and 2)	<ul style="list-style-type: none"><li>- low occupancy rooms: ballast replacement (Scenario no. 1)</li><li>- high occupancy rooms: DALI control system with new LED luminaires (Scenario no. 2)</li></ul>
SC1+2+3	<ul style="list-style-type: none"><li>- high occupancy rooms: DALI control system with new LED luminaires (Scenario no. 2)</li><li>- low occupancy rooms: ballast replacement (Scenario no. 1) for areas that need to maintain the same lighting level (e.g. medical offices);</li><li>- Re-lamping with new LED lamps (Scenario no. 3) for rooms where no restrictions are imposed to the lighting level (e.g. bathrooms, technical rooms)</li></ul>
SC2A	<ul style="list-style-type: none"><li>- Limited to corridors: DALI control system with new LED luminaires (Scenario 2)</li></ul>

Simulations allowed to assess how effective each of the combinations may be, as compared to the measured and simulated current electric consumption due to lighting.




# LIGHTING MODELLING

Software used for simulation: Relux


Calculation methods: Radiosity algorithm.

Experimental model calibration (lux-meter point measurements).

Adjustment of parameters: walls reflectivity, transmission coefficient of windows.






1-	143 lx
2-	152 lx
3-	74 lx
4-	80 lx



Requirements: thresholds for lighting levels; luminance uniformity in order to avoid glare.

# SIMULATION PHASE

Current lighting levels will be guaranteed in task areas even after renovation has been accomplished; dimming was used to adjust lamps' power according to real needs (i.e. natural lighting and deployment of fixtures). Energy savings were derived from operation time and actual power of new lamps.




## ESTIMATED ENERGY SAVINGS

Scenarios no. 1 and 3 were called “soft” scenarios: ballast replacement and lamping replacement.

Scenario no. 2 was called “hard” scenario: replacement of lamps with led fixtures and Dali control of the dimming level.

Scenario	Current consumption [KWh]	Scenario consumption [KWh]	Saving [KWh]	Saving %	Renovation Cost [€]
Scenario no. 1	58783	50740	8043	13.68%	6359
Scenario no. 2 (13011:1974)	58783	31102	27681	47.09%	82699
Scenario no. 2 (EN12464-1)	58783	37983	20800	35.38%	82699
Scenario no. 2A (13011:1974)	58783	40431	18352	31.22%	49538
Scenario no. 2A (EN12464-1)	58783	43365	15418	26.23%	49538
Scenario 3	58783	23210	35572	60.52%	24355
Scenario 1+2 (13011:1974)	58783	35370	23413	39.83%	55897
Scenario 1+2 (EN12464-1)	58783	35332	23451	39.89%	55897
Scenario 1+2+3 (13011:1974)	58783	32253	26530	45.13%	80253
Scenario 1+2+3 (EN12464-1)	58783	35332	23451	39.89%	80253

# IMPLEMENTATION OF THE DALI CONTROL



Luminaire Groups: 4


Motion Sensors : 4

Multi Sensors : 1

Dali Control : 1

Led Dimmable Fixtures : 10

Cost (Including Manpower) :  
58.41 €/m<sup>2</sup>




# COST OF LIGHTING RENOVATION

Average cost of scenario no. 1: 2.40 €/m<sup>2</sup>.


Average cost of scenario no. 2: 58.41 €/m<sup>2</sup>.

Average cost of scenario no. 3: 7.59 €/m<sup>2</sup>.

Savings vs renovation cost



Discounted payback period



## CONCLUSIONS

1. “Soft” scenarios have short payback periods but also low energy savings;
2. “hard” and combined renovations scenarios have longer payback periods but they will guarantee higher energy savings and the installation of an almost completely renewed lighting system, so they are worth the investment.

Thank you for your kind attention

A. Carbonari, L. Nobili, R. Pontoni

**DICEA Department - Division of Building Technologies**

**Research Team: Building Construction and Automation**

[www.univpm.it](http://www.univpm.it)

**Polytechnic University of Marche - Ancona, Italy**

